

Government of Bihar
Public Health Engineering Department

District Level Water Testing Laboratory:- Siwan

Simple Collected by-Divine public School Pathardei

Simple Receiving date:-29.04.2023

1	Date Of Testing	Block	Panchyat	Village	Name of Scheme	Parameters														
						pH	Turb.	EC	TDS	TH	Ca	Mg	Cl	Alka.	Fe	NO ₃	SO ₄	F	As	Total Coli
1	3.05.2023	Ziradei	Jamapur	Pathardei	Divine public School Pathardei	7.02	1.1	-	110	65	26	-	40	70	0.16	BDL	BDL	0.14	0.0	<1.1
Desirable Limits						6.5-8.5	5.0	-	500	200	75	30	250	200	0.3	45	200	1.0	0.01	
Permissible Limits						8.5	NR	-		600	200	100	1000	600	0.3	NR	400	1.5	NR	

All parameters are under disrable limits

Ankit Singh
3/5/2023
Lab Assistant
LAB ASSISTANT
P H Division Siwan